

December 30, 2019

Attention: Emma Smith
AAONE
PO BOX 91072
BURNHAMTHORPE PO
TORONTO, ON M9C 5N5

The design submission, tracking number 2019-08276, originally received on December 08, 2019 was surveyed and accepted for registration as follows:

CRN : 0C13492.52 Accepted on: December 30, 2019
Reg Type: RENEWAL Expiry Date: December 02, 2029
Drawing No. : SCOPE OF REGISTRATION-RENEWAL
Fitting type: VALVES
Design registered in the name of : VIEGA LLC A SUBSIDIARY OF VIEGA HOLDING GMBH & CO KG

The registration is conditional on your compliance with the following notes:


As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction is ASME B31.1, ASME B31.3, ASME B31.9

- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3343 or fax (780) 437-7787 or e-mail Tang@absa.ca.

Sincerely,



TANG, TAO, P. Eng.
DOP Cert. No. D00008848

STATUTORY DECLARATION Registration of Fittings

I, Frank Shingleton, Product Compliance Manager of Viega LLC a subsidiary of Viega Holding GmbH & Co. KG located at Viega Platz 1 57428 Attendorn Germany

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting. VIEGA viega

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act (check one)

[X] comply with the requirements of ASME B31.1; ASME B31.3 & ASME B31.9 which specifies the dimensions, materials of construction, pressure/temperature ratings and identification marking of the fittings, or

[] are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with as supported by the attached data which identifies the dimensions, materials of construction, pressure/temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified by the following authority, DQS GmbH as being suitable for the manufacture of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are Category - C Viega ProPress Stainless (304 & 316)

In support of this application, the following information, calculations and/or test data are attached:

PL-PPS-PPM-0208/ 1-877-VIEGA-NA ; 704753-CAT-0110 U3 & U4 Stainless Steel ; Viega ProPress Stainless CRN Additions 11-2013

DECLARED before me at Broomfield in the state of Colorado (USA) this 8th day of November, 2019

EDWINA S. HOWARD NOTARY PUBLIC STATE OF COLORADO NOTARY ID 20174004143 MY COMMISSION EXPIRES JANUARY 27, 2021

(print) Edwina S. Howard (a Commissioner of Oaths or Notary Public) (sign) Edwina S. Howard (a Commissioner of Oaths or Notary Public)

(signature of applicant)

For ABSA Office Use Only:

NOTES:

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Clause 4.2, and is accepted for registration in Category C

Registration Number: OC 13492-52


(Signature of the Administrator/SCO)

Date Registered: DEC 30 2019

Expiry Date: Dec 27 2021

The information you provide is necessary for the administration of the programs as required by the Alberta Safety Codes Act and Regulations in the Pressure Equipment Discipline.

Scope of CRN Registration - RENEWAL CRN: 0C13492.5C
VIEGA ProPress Stainless Steel

Logo:	
Renewal Product Catalogs: PL-PPS-PPM-0208/ 1-877-VIEGA-NA 704753-CAT-0110 U3 & U4 Stainless Steel Viega ProPress Stainless CRN Additions 11-2013	
Design Code:	ASME: B31.1, B31.3, B31.9
Material:	ASTM A312 Grade 304/316
Sizes – Design Pressure @Design Temp.	½", ¾", 1" 200psi @ (4°F to 250 °F)
Sizes – Design Pressure @Design Temp.	1¼", 1½", 2", 2½", 3", 4 150psi @ (4°F to 250 °F)
O-RING	EPDM,FKM
Additional Germany locations stated under ISO Certificate 535734	Viega Holding GmbH & Co. KG
Additional USA locations stated under ISO Certificate 13489	Viega LLC

The scope of the registration and the design parameters, such as pressure and temperature of the CRN renewal submission are the same as the original CRN submissions.

ABSA	
SAFETY CODES ACT - PROVINCE OF ALBERTA	
REGISTRATION OF FITTINGS	
REGISTRATION NO.	0C13492.52
DWG. NO. or CAT. NO.	<i>Scope of Registration - Renewal</i>
TYPE OF FITTINGS	<i>Valves</i>
DEC 30 2019	INITIALS <i>Tao Tang</i>
Date	TAO TANG, P.Eng. DESIGN SURVEY ENGINEER