

# viega

## SEISMIC CERTIFICATE OF COMPLIANCE

Product Line: MegaPress and ProPress

Qualified to CBC-2019 Section 1705A.13.2/3 and IBC 2018 Section 1705.13.2/3

Seismic Parameters:  $S_{DS} = 2.0g$  at  $T/h = 1.0$



Certified Product Lines				
Product Line	Material	Pipe Size	Pipe Schedule	Fluid Pressure
MegaPress	Carbon Steel	1/2" - 4"	Sch. 10 - Sch. 40 (IPS)	Air - 200psi Water - 300psi
	Stainless Steel 304/316			
ProPress	Stainless Steel 304/316		CTS	
	Copper			

**Qualified by Shake-Table Testing at SEESL in May 2016 (Report UB CSEE/SEESL-2016-05) and December 2021 (Report SEESL-2021-24).**

See WEGAI Seismic Certification Letter for details on the product line and seismic installation requirements.

### **Certification:**

This document certifies the above-mentioned MegaPress and ProPress product lines manufactured by Viega meets the requirements for special seismic certification of IBC-2018/CBC-2019 with an Importance Factor of 1.5.



3.28.2022

Seismic certification and analytical work performed by W.E. Gundy & Associates, Inc. ([www.wegai.com](http://www.wegai.com)). Adam Franklin, Registered Professional Engineer, California

