

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

Issued to: VIEGA L L C
585 Interlocken Blvd
Broomfield CO, 80021 US

**This is to certify that
representative samples of** FITTINGS, RUBBER GASKETED
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/CAN/UL 213-Standard for Safety for Rubber
Gasketed Fittings for Fire Protection Service

ANSI/UL 852-Standard for Safety for Metallic Sprinkler Pipe
for Fire Protection Service


ULC/ORD-C199S-94-The Other Recognized Document for
Light Wall steel Pipes for Sprinkler Systems for Fire
Protection Service

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements


Models:

USL, CNL Rubber gasketed fittings of the following types, sizes and rated pressures:

Press Fittings

ProPress 304 rubber gasketed fittings in the following types, sizes and rated pressures are intended for use with Viega Eco pipe and Viega 304 stainless steel sprinkler pipe and are to be installed with a Viega approved Electro-Hydraulic Press Tool in accordance with the manufacturer's installation instructions.

Model	Type	Size, in.	Rated Pressure, Psig (kPa)
6011	Adapter (P x MNPT)	1/2 x 1/2, 1/2 x 3/4; 3/4 x 1/2, 3/4 x 3/4, 3/4 x 1; 1 x 3/4, 1 x 1; 1-1/4 x 1-1/4; 1-1/2 x 1-1/2; 2 x 2	175 (1210)
6012	Adapter (P x FNPT)	1/2 x 1/2; 3/4 x 1/2, 3/4 x 3/4; 1 x 1/2, 1 x 3/4, 1 x 1; 1-1/4 x 1-1/4; 1-1/2 x 1-1/4, 1-1/2 x 1-1/2; 2 x 1, 2 x 1-1/2, 2 x 2	175 (1210)
6056	Cap	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6015	Coupling	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

	(P x P)		
6015.5	Slip Coupling (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6059	Flange Adapter (P x F)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6016	90 Degree Elbow (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6016.1	90 Degree Elbow (FTG x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6026	45 Degree Elbow (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)

Model	Type	Size, in.	Rated Pressure, Psig (kPa)
6026.1	45 Degree Elbow (FTG x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6018	Tee (P x P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
6018	Reducing Tee (P x P x P)	3/4 x 3/4 x 1/2; 1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4, 1-1/4 x 1-1/4 x 1; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1, 2 x 2 x 1-1/2	175 (1210)
6017.2	Reducing Tee (P x P x FNPT)	3/4 x 3/4 x 1/2, 3/4 x 3/4 x 3/4; 1 x 1 x 1/2, 1 x 1 x 3/4;	175 (1210)

B. Mahlen

Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

		1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4, 1-1/4 x 1-1/4 x 1; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1	
6015.1	Reducer (FTG x P)	3/4 x 1/2; 1 x 1/2, 1 x 3/4; 1-1/4 x 1/2, 1-1/4 x 3/4, 1-1/4 x 1; 1-1/2 x 1/2, 1-1/2 x 3/4, 1-1/2 x 1; 2 x 1/2, 2 x 3/4, 2 x 1, 2 x 1-1/2	175 (1210)
6060	Union (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)


P – Press

F - Flange

FNPT – Female NPT Threads

MNPT – Male NPT Threads

FTG – Pipe End Fitting



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

ProPress 316 rubber gasketed fittings in the following types, sizes and rated pressures are intended for use with Viega Eco pipe and Viega 316 stainless steel sprinkler pipe and are to be installed with a Viega approved Electro-Hydraulic Press Tool in accordance with the manufacturer's installation instructions.

Model	Type	Size, in.	Rated Pressure, Psig (kPa)
4011	Adapter (P x MNPT)	$1/2 \times 1/2$, $1/2 \times 3/4$; $3/4 \times 1/2$, $3/4 \times 3/4$, $3/4 \times 1$; $1 \times 3/4$, 1×1 ; $1-1/4 \times 1-1/4$; $1-1/2 \times 1-1/2$; 2×2	175 (1210)
4012	Adapter (P x FNPT)	$1/2 \times 1/2$; $3/4 \times 1/2$, $3/4 \times 3/4$; $1 \times 1/2$, $1 \times 3/4$, 1×1 ; $1-1/4 \times 1-1/4$; $1-1/2 \times 1-1/4$, $1-1/2 \times 1-1/2$; 2×1 , $2 \times 1-1/2$, 2×2	175 (1210)
4056	Cap	$1/2$, $3/4$, 1 , $1-1/4$, $1-1/2$, 2	175 (1210)
4015	Coupling (P x P)	$1/2$, $3/4$, 1 , $1-1/4$, $1-1/2$, 2	175 (1210)
4015.5	Slip Coupling (P x P)	$1/2$, $3/4$, 1 , $1-1/4$, $1-1/2$, 2	175 (1210)
4059	Flange Adapter (P x F)	$1/2$, $3/4$, 1 , $1-1/4$, $1-1/2$, 2	175 (1210)
4016	90 Degree Elbow	$1/2$, $3/4$, 1 , $1-1/4$, $1-1/2$, 2	175 (1210)

B. Mahlen

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

	(P x P)		
4016.1	90 Degree Elbow (FTG x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
4026	45 Degree Elbow (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)

Model	Type	Size, in.	Rated Pressure, Psig (kPa)
4026.1	45 Degree Elbow (FTG x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
4018	Tee (P x P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
4018	Reducing Tee (P x P x P)	3/4 x 3/4 x 1/2; 1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4, 1-1/4 x 1-1/4 x 1; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1, 2 x 2 x 1-1/2	175 (1210)
4017.2	Reducing Tee (P x P x FNPT)	3/4 x 3/4 x 1/2, 3/4 x 3/4 x 3/4; 1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4, 1-1/4 x 1-1/4 x 1; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4, 1-1/2 x 1-1/2 x 1; 2 x 2 x 1/2, 2 x 2 x 3/4, 2 x 2 x 1	175 (1210)
4015.1	Reducer (FTG x P)	3/4 x 1/2; 1 x 1/2, 1 x 3/4; 1-1/4 x 1/2, 1-1/4 x 3/4, 1-1/4 x 1;	175 (1210)

B. Mahlen

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20130905
Date 2021-April-26

		1-1/2 x 1/2, 1-1/2 x 3/4, 1-1/2 x 1; 2 x 1/2, 2 x 3/4, 2 x 1, 2 x 1-1/2	
4060	Union (P x P)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)


P – Press

F - Flange

FNPT – Female NPT Threads

MNPT – Male NPT Threads

FTG – Pipe End Fitting



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

