

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20021022
Date 2021-October-01

Issued to: VIEGA L L C
585 Interlocken Blvd
Broomfield CO, 80021 US

This is to certify that representative samples of FITTINGS, RUBBER GASKETED

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 213 - Rubber Gasketed Fittings for Fire-Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20021022
Date 2021-October-01


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:

Rubber gasketed fittings of the following types, sizes and rated pressures:

Zero Lead ProPress rubber gasketed fittings in the following types, sizes and rated pressures are intended for use with copper tube, Type K, L and M and are to be installed with a Viega approved Electro-Hydraulic Press Tool in accordance with the manufacturer's installation instructions.

Model	Type	Size, in.	Rated Pressure, psig (kPa)
2925.5ZL	90° Elbow Drop w/ wall plate (P x FNPT)	3/4 x 3/4	175 (1210)
2917.2ZL	Tee (P x P x FNPT)	3/4 x 3/4 x 1/2, 3/4 x 3/4 x 3/4; 1 x 1 x 1/2, 1 x 1 x 3/4; 1-1/4 x 1-1/4 x 1/2, 1-1/4 x 1-1/4 x 3/4; 1-1/2 x 1-1/2 x 1/2, 1-1/2 x 1-1/2 x 3/4; 2 x 2 x 1/2, 3/4	175 (1210)
2911ZL	Male Adapter (P x MNPT)	3/4 x 1/2, 3/4 x 3/4, 3/4 x 1; 1 x 3/4, 1 x 1, 1 x 1-1/4; 1-1/4 x 1, 1-1/4 x 1-1/4; 1-1/2 x 1-1/4, 1-1/2 x 1-1/2; 1-1/2 x 2;	175 (1210)
2912ZL	Female Adapter (P x FNPT)	3/4 x 1/2, 3/4 x 3/4; 1 x 1/2, 1 x 3/4, 1 x 1, 1 x 1-1/4; 1-1/4 x 1/2, 1-1/4 x 1, 1-1/4 x 1-1/4, 1-1/4 x 1-1/2; 1-1/2 x 1-1/4, 1-1/2 x 1-1/2; 2 x 2	175 (1210)
2967ZL	Di-Electric Union (P x FNPT)	3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
2914.2ZL	90° Elbow (P x FNPT)	3/4 x 1/2, 3/4 x 3/4; 1 x 1/2, 1 x 1; 1-1/4 x 1-1/4; 1-1/2 x 1-1/2; 2 x 2	175 (1210)
2960ZL	Union (P x P)	3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
2962ZL	Union (P x FNPT)	3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
2965ZL	Union (P x MNPT)	3/4, 1, 1-1/4, 1-1/2, 2	175 (1210)
2959.5ZL	Adapter Flange (P x Flange)	1, 1-1/4, 1-1/2, 2	175 (1210)
2915.1ZL	Reducer (FTG x P)	1-1/2 x 1/2; 2 x 1/2, 3/4	175 (1210)



Bruce Mahrenholz, Director North American Certification Program

UL LLC




Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX6157
Report Reference EX6157-20021022
Date 2021-October-01

All model Propress rubber gasketed fittings are suitable for use in dry pipe systems for temperatures to -40 degree F.

P - Press
F NPT - Female National Pipe Thread
M NPT - Male National Pipe Thread
FTG – Copper tube end (fitting)



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

